



Hot Work Permit/Fire System Bypass Request

Permit # _____

It is the responsibility of the UTSC PM or Supervisor to submit this request form two (2) working days in advance of any hot work or fire system bypass date. A fire system bypass cannot be performed without approval from the Manager of Security Systems & Services.

UTSC PM or Supervisor is responsible for providing staff for fire watch duties during the entire bypass period. UTSC PM or Supervisor is responsible for ensuring the work area and all adjacent areas are inspected for at least 60 minutes after the work has been completed and are found to be fire safe.

Approved by: _____ **Requested by:** _____
Campus Safety Management UTSC PM or Supervisor

Date permit issued: _____ **Phone Number:** _____

Date of work: _____ Start Time: _____ End Time: _____

Building: _____ Room Number: _____

Location: _____ Is this a confined/enclosed space? _____

Who is doing the work (Contractor): _____

Hot Work	Fire System Bypass
Is hot work being done? If yes, what type: _____	Does any part of the fire system require bypass? _____
CheckList: <input type="checkbox"/> Has the equipment been checked and in good repair? <input type="checkbox"/> Any flammable/combustible liquids in the area? <input type="checkbox"/> Will they be covered? <input type="checkbox"/> Will they be moved? <input type="checkbox"/> Is the appropriate extinguisher fully charged and on hand? <input type="checkbox"/> Are communications (radio/telephone) in place to sound the alarm if needed	If yes, indicate which system needs to be bypassed: <input type="checkbox"/> Fire Detection <input type="checkbox"/> Sprinkler <input type="checkbox"/> Other Device Location: _____ _____ Reason for bypass: _____ _____ Fire watches are required for all system bypasses